

**TABLE H-15  
INDOOR PORTABLE TANK STORAGE**

Class liquid	Storage level	Protected storage maximum per pile		Unprotected storage maximum per pile	
		Gal.	Ht.	Gal.	Ht.
IA	Ground and upper floors Basement	Not permitted Not permitted		Not permitted Not permitted	
IB	Ground and upper floors Basement	20,000 7 ft. Not permitted		2,000 7 ft. Not permitted	
IC	Ground and upper floors Basement	40,000 14 ft. Not permitted		5,500 7 ft. Not permitted	
II	Ground and upper floors Basement	40,000 14 ft. 20,000 7 ft.		5,500 7 ft. Not permitted	
III	Ground and upper floors Basement	60,000 14 ft. 20,000 7 ft.		22,000 7 ft. Not permitted	

*Note 1: When 2 or more classes of materials are stored in a single pile, the maximum gallonage permitted in that pile shall be the smallest of the 2 or more separate maximum gallonages.*

*Note 2: Aisles shall be provided so that no portable tank is more than 12 ft. from an aisle. Main aisles shall be at least 8 ft. wide and side aisles at least 4 ft. wide.*

*Note 3: Each pile shall be separated from each other by at least 4 ft.*